

CERTIFIED ENVIRONMENTAL PROFESSIONAL IN THE LEACHATE TREATMENT PLANT OPERATION (CePLTPO)

GUIDANCE DOCUMENT ON THE PREPARATION OF FIELD TRAINING REPORT

(Note: This guidance document is applicable to both solid waste landfills and transfer stations)

1. GENERAL INFORMATION

1.1 Introduction

The preparation of Field Training Report (FTR) is the final step that a CePLTPO candidate needs to go through to complete the certification process. The FTR is a document that provides evidence the following has taken place:

- (i) The landfill management has undergone a “**behavioral change**” in the manner the environmental regulatory requirements and environmental issues associated with landfill operation are viewed and managed. (Note: Behavioral change is synonymous with Kirk Patrick’s level 3 training effectiveness assessment process)
- (ii) The landfill management has successfully implemented the **environmental mainstreaming tools** (EMTs) en route towards cultivating the culture of self regulation within the landfill organization in and management.

1.2 The FTR: A collaborative effort

Successful preparation of the FTR demonstrates fruitful collaborative efforts between the CePLTPO candidate and the landfill management in the implementation of environmental mainstreaming tools in the management and operation of the landfill. The environmental mainstreaming success cannot be achieved and the FTR successfully prepared without major contributions from both parties: the CePLTPO candidate and the landfill management. Without the candidate’s persistent efforts to explore for ideas for change, no practical improvement projects can be formulated. On the other hand, without strong support from the landfill management, the candidate’s ideas and improvement initiatives cannot be realized. The FTR embodies both the **management improvement initiatives** (MIIs) as well as the **technical improvement initiatives** (TIIs).

The FTR examiners are looking for the implementation of the MIIs and TIIs which results in the successful operation of the LTS and overall improvement in the environmental regulatory compliance of the landfill.

1.3 Minimum training period

As a minimum training requirement, the candidates are required to undergo field training on operating and maintaining an LTS at a landfill for a period of six (6) months.

1.4 Where to send the FTR

The completed FTR must be sent to the following address:

The Director
Environment Institute of Malaysia (EiMAS)
Department of Environment
Universiti Kebangsaan Malaysia
Locked Bag No. 24
43600 BANGI, SELANGOR
(Attn: Certification Center)

1.5 Clarifications on FTR

For any general clarifications on FTR, please contact the following officers at the Competency & Industry Certification Center, EiMAS:

Mr. Mohd Aizuddin Ab Razak; aizuddin@doe.gov.my
Ms. Noor Huda Mohd Yusof; huda@doe.gov.my

1.6 Extension of FTR submission period

Extensions for FTR submission period may be granted only for the following situations:

1. Health reasons, where the candidate is sick or unable to work for a period of more than 3 months within the FTR preparation period. Evidence in the form of a letter from a medical doctor is required.
2. Pregnancy and related reasons, where the candidate is pregnant or has given birth.
3. LTS non operational issues, where the LTS that the candidate is in charge of is still under construction, or is being commissioned, or is taken out of operation for maintenance. The latter covers a period of more than 3 months.

The request for extension must be made before the expiry of the FTR preparation period. If an extension is granted, only one extension, up to a maximum of one year may be given.

1.7 Purpose of this Guidance Document

This Guidance Document describes the documentation requirements for FTR preparation and provides detailed advice, direction, instruction, and suggestion on what to write in each of the FTR chapters. This step-by-step guide if adhered to closely, should produce quality FTR that can comfortably be approved by EiMAS.

2. FTR SPECIFICATIONS AND FORMAT

The FTR must follow the general specifications and format as follows:

2.1 FTR specifications

2.1.1 Covers and binding

The FTR must be bound preferably in hard cover (BLUE or BLACK WITH GOLD LETTERING). The front cover of the FTR shall follow the example given in Appendix A.

2.1.2 Language of FTR

The FTR may be written in English or Bahasa Malaysia

2.1.3 Typeface and font size

Typeface to be used is Arial. Font size of 12 point shall be used for the main body of the text and 14 for the cover

2.1.4 Margins and spacing

The margin on the document must comply with the specifications below:

Top – 20 mm

Bottom – 40 mm

Left – 40 mm

Right – 25 mm

2.1.5 Text

Text must be: typed on one side of the paper only, one and a half-spaced, left-right justified. For captions of figures and tables, single spaces can be used.

2.1.6 Pagination

Every page except the title page must be numbered; PRELIMINARY PAGES are to be numbered in lower case Roman numerals (i, ii, iii, ...); and MAIN TEXT pages are to be numbered at the center of the page (1, 2, 3..) and all pages must be numbered consecutively and continuously.

2.1.7 Number of pages

The FTR must contain a minimum of 20 pages (excluding executive summary, illustrations, photographs, appendices, or figures).

2.1.8 Photographs

Photographs must be clear and printed in COLOR and appropriately captioned.

2.1.9 Table, figures, and drawings

All tables, figures, and drawings must be clear, legible, appropriately labeled and numbered.

2.1.10 Number of copies

One hard copy of the FTR and one soft copy burnt on a compact disc must be submitted.

2.2 FTR format

2.2.1 FTR structure

The structure of the FTR is based on a standard format which contains the following sections:

A. Preliminary pages

B. Main text

C. Appendices

3. DETAILS OF WHAT EACH SECTION CONTAINS

A. PRELIMINARY PAGES

The preliminary pages shall include at least the following:

a. General information on the candidate

A1. Name of CePLTPO candidate:

.....

A2. Contact address:

.....

.....

.....

A3. Designation:

.....

A4. Date of attending the CePLTPO course:

.....

A5. Name and address of the landfill or transfer station where you underwent the field training on LTS operation and maintenance:

i) Name:.....

ii) Address:.....

.....

.....

A6. Period of field training:

.....

A7. Contact officer in your landfill or transfer station company/organization (e.g. Human Resource Manager at the headquarters) who could verify your training experience:

Name:.....

Designation:.....

Phone number:.....

Fax number:.....

E-mail address:.....

b. Verification (to be filled out by the CePLTPO candidate's supervisor)

"I hereby declare that (Mr/Ms).....has completed the six months field training as required and the information provided in the FTR is true to my best knowledge"

Name of landfill or transfer station official or supervisor at the Headquarters:

.....

NRIC number:

Designation :.....

Signature: Date:

Landfill or transfer station company's/organization's official stamp:

c. Declaration (to be filled out by the CePLTPO candidate)

"I declare that the entire FTR is the product of my own work and all the facts stated in it and the accompanying information are true and correct and that I have not

withheld or distorted any material facts or included any materials plagiarized from other FTRs”

Name of candidate:..... NRIC number:

Designation :.....

Signature: Date:

Landfill organization’s stamp:

(Note:

The verification and declaration must be type written using the official letterhead of the landfill organization where the candidate is attached to)

B. MAIN TEXT

The main text or body of the FTR shall include at least the following chapters.

CHAPTER 1: INTRODUCTION

1.1 Background of organization/company

In this subchapter you are required to briefly **introduce** your landfill or transfer station company, its service area, location, years of operation, operating hours, capacity, life expectancy, employee strength, etc.

1.2 Landfill or transfer station company’s/organization’s environmental commitment

This subchapter summarizes the implementation of **environmental mainstreaming tools** (EMTs) of the Guided Self Regulation (GSR) approach. The reporting of the EMT implementation tool is explained below.

1.2.1 Environmental policy (EP)

In this subchapter, you are required to reproduce an extract of your landfill or transfer station company’s/ organization’s Environmental Policy (EP). The policy must **stand on its own** and focus only on environmental aspects and must not be combined with other aspects such as safety, etc. Mention the date the policy was made and identify whether the EP is an existing policy or a new policy which has been developed during your FTR preparation period. If your landfill organization’s existing EP is weak on the environmental aspects, or outdated, or the environmental aspects are only incorporated in other policies, you must grab the opportunity now while preparing your FTR, to initiate the review of the policy or preparation of a new one. Explain how and where you were involved in the EP review or its preparation.

EXAMPLE



Fig 1.1: Environmental policy of Murni Landfill Sdn Bhd

(note: Take a photo of the official EP with the CEO's/president's/manager's signature or retype it and have it formally endorsed)

1.2.2 Environmental facilities (EFs)

In this subchapter you are required to describe the Environmental facilities (EFs) provided, installed, and maintained at your landfill or transfer station premise. Although the focus of the FTR is on the LTS, you are also required to include in your discussion, air pollution control systems (APCS), noise abatement system, performance monitoring equipment, on-line instrumentation system, and associated support facilities such as LTS laboratory facilities.

1.2.3 Environmental budgeting (EB)

In this subchapter you are required to explain in general, the **budget allocation** provided by your landfill or transfer station organization for the purpose of taking measures to comply with the environmental company/ regulatory requirements, for providing the EFs as described in 1.2.2, for LTS operation, and for implementing other environmental-related efforts. If relevant and appropriate, you can provide a table to summarize the budget information.

1.2.4 Environmental competency (EC)

1.2.4.1 Training of environmental personnel

In this subchapter you are required to provide an organizational structure and identify on it all the **relevant staff** (including yourself as the CePLTPO candidate) who are involved directly or indirectly with the operation, maintenance, and monitoring of the LTS. Training plan to improve environmental competency of the relevant staff must be discussed.

EXAMPLES

Note: The box clored in red is the placement of the Candidate CePLTPO

Fig 1.2: Organizational structure showing staff involved in LTS operation and supervision

Table 1.1: LTS staff training plan

Staff name	Main LTS responsibilities	Relevant course	Planned course date

(note: courses can be held in-house or staff can be sent to attend external courses)

1.2.4.2 Functions of CePLTPO

In this subchapter you are required to discuss and provide a certified copy of your list of duties (e.g. **job description-JD**) where it shows the LTS performance monitoring functions or other functions related to LTS operation and supervision as one of your core duties. The JD can be placed in this subchapter or may also be placed in the Appendix, if it occupies several pages.

EXAMPLE



Fig 1.3: Job description of the CePIETSO candidate

1.2.5 Environmental committees

1.2.5.1 Environmental performance monitoring committee (EPMC)

In this subchapter you are required to provide an organizational structure of the environmental performance monitoring committee (EPMC) and its terms of reference (TOR) or functions. The EPMC, which is at the **working level** must meet monthly or at a minimum once in a quarter. Provide the date when the EPMC was established, designations/posts of its committee members and its meeting dates within the FTR preparation period. The EPMC members must be officially appointed by the chief operating officer (CEO) or president of your landfill company or official of similar rank. A certified copy the minutes of one of the EPMC meetings must be provided in the Appendix as evidence.

EXAMPLES



Fig 1.4: Organizational structure of the EPMC

Table 1.2: Terms of reference of EPMC

Terms of reference of EPMC	
1.....	
2.....	
3.....	

Table 1.3: Record of EPMC meetings

Date of meeting	EPMC members present

Prepared by:.....
(CePLTPO)
Signature.....Date.....

1.2.5.2 Environmental regulatory compliance monitoring committee (ERCMC)

In this subchapter you are required to provide organization chart of the policy level committee which must be **chaired by the CEO** of the landfill or transfer station company. The committee meets at a minimum once a year. The information includes the post/designation of the chairperson of the ERCMC and the posts of the committee members.

EXAMPLE



Fig 1.5: Organizational structure of the ERCMC

1.2.6 Environmental reporting and communication (ERC)

In this subchapter you are required to describe the **communication channel** established for reporting LTS issues and other environmental concerns which require prompt actions to be taken. You must also describe scheduled internal reporting requirements on regulatory compliance status of your landfill or transfer station to the top management.

1.2.7 Environmental transparency (ET)

If your landfill or transfer station company/organization issues any kinds of report (such as an annual report) that includes an environmental section or discussion on environmental regulatory compliance or the like, you may describe the **proactive efforts** in ET undertaken in this subchapter. Other efforts may include installation of environmental compliance billboard and corporate social responsibility (CSR) activities.

CHAPTER 2: PERFORMANCE MONITORING OF LEACHATE TREATMENT SYSTEM

2.1 Landfill or transfer station activities and leachate generation

In this subchapter, you are required to briefly explain the activities and operations carried out at your landfill or transfer station identify the **leachate generation points**, and the quality and quantity of leachate generated. Provide a table of that summarizes the characteristics of the **raw leachate** (quality and quantity) (example given below) covering the FTR preparation period. Briefly discuss the type of leachate (acetogenic or methanogenic), **biodegradability** of your leachate and **nutrient requirements** (or nutrient deficiency) and identify the significant leachate parameters.

EXAMPLES





Fig 2.1: Landfilling process flowchart and leachate generation points

Table 2.1: Raw leachate characteristics

Parameter	Range	Average	Remarks
Q, m ³ /d			
pH, value			
BOD, mg/L			
COD, mg/L			
SS, mg/L			
NH ₃ , mg/L			
Others...			

2.2 Description of LTS

In this subchapter you are required to describe and discuss the **components** of the LTS (unit processes and unit operations) installed in your landfill to treat the leachate you described in 2.1. It is recommended that you present a block diagram and pictures of the LTS components. Additionally, a table (example given below) should be used to present information on the relevant **design and operating details** such as hydraulic retention time (HRT), sludge age, F/M ratio, etc.) the control ranges, and other relevant details of the LTS components.

EXAMPLES



Fig 2.2: LTS block diagram/flowchart

Table 2.2: LTS design and operating details

Component	Function	Design details	Control range	Remarks
EQ		HRT:		
pH adjustment tank		HRT:		
Metal precipitation tank		HRT:		
Coagulation tank		HRT:		
Flocculation tank				
Chemical solids clarifier		HRT: SOR:		

		WOR:		
Activated sludge		Sludge age: F/M: MLSS: MLVSS: SOUR: SVI, etc.		
Biological solids clarifier (secondary clarifier)		SOR: WOR: SLR:		
Others...				

2.3 Conduct of LTS performance monitoring

2.3.1 Situation before attending CePLTPO course

In this subchapter, you are required to describe how the LTS **performance** and environmental regulatory compliance issues were being monitored before you attended the CePLTPO course.

2.3.2 Changes instituted

In this subchapter, you you are required to describe how and what **changes** were made through your efforts or intervention to the way LTS is operated and monitored in your premise, to be in line with the procedure taught in the CePLTPO course. The changes cover both the “software aspects” and “hardware aspects” which may include the following:

- New or revised PM field checklists/log sheets (additional parameters, revised sampling frequency)
- New or revised internal reporting format
- New communication/reporting channel for LTS emergency situations (equipment breakdown, upsets, etc)
- LTS hardware improvements (small modifications or upgrading)
- Purchase of PM instruments
- New or revised procedure for PM data analysis
- Use of performance monitoring reports (PMR)

Any of the above items when mentioned and discussed in the FTR must be provided with evidence placed in the Appendices. For example, provide a photocopy of the handwritten PM field log sheets containing two signatures used by your LTS technicians.

CHAPTER 3: DISCUSSION OF PERFORMANCE MONITORING ACTIVITIES AND RESULTS

In this chapter you must provide a thorough discussion of the **performance monitoring activities and data** obtained within the FTR preparation period. From the information on the unit processes and unit operations of your LTS as described in 2.2. the relevant performance monitoring parameters must be identified. You must then compare the PM data obtained with the recommended ranges. Based on the

comparison you must make a brief statement whether the processes that were supposed to occur in the treatment components actually occurred in an optimal fashion. Any abnormality observed or data falling out of the recommended ranges must be explained. The discussion in this chapter is made primarily through the use of graphical plots of all the PM parameters.

As a guide, the table below gives a summary of typical LTS(PCP) components and graphs of PM parameters commonly associated with the monitoring of the PCP components.

Component	Graphs "X vs Y" to be plotted	Other relevant activities	Control range, if applicable
Equalization	Q, pH, BOD, COD, N, P, metals	-	-
Cooling	T		
pH adjustment	pH	Maintenance of acid/alkali dosing system	
Coagulation and flocculation	pH	Conducting Jar test; dosing calculations, maintenance of coagulant dosing system	
Chemical precipitation (hydroxide, sulfide, carbonate, sulfate, etc.)	pH	Maintenance of chemical dosing system	
Dissolved air flotation	A/S ratio; pH, P	Observation of skimmer speed; coagulation/flocculation aspects if carried out.	
Ion exchange	Metals, pH	Breakthrough time monitoring; Maintenance of chemical dosing system; regenerant management	
Adsorption	COD, P	Pressure; Breakthrough monitoring	
Chemical oxidation	ORP, pH	Maintenance of chemical dosing systems	
Redox	ORP, pH	Maintenance of chemical dosing systems	
Electrocoagulation	Voltage, COD	-	
Fenton's process	pH, COD	-	
Membrane filtration	TMP, pH, SS, turbidity	Chemical cleaning	
Media filtration	P, SS, turbidity	-	
Evaporation	T, P	-	

Note: List not exhaustive; T = temperature; TMP = trans membrane pressure; Graphs to be plotted depend on a case to case basis.

Summary of typical LTS(BP) components and graphs of PM parameters commonly associated with the monitoring of the BP components is given in the table below.

Component	Graphs to be plotted	Other relevant activities	Control range, if applicable
Equalization	Q, pH, BOD, COD, SS		
Primary clarifier	SS, turbidity	Calculation of SOR, SLR, WOR	
Lagoon system	pH, DO (for aerobic system), SS, ORP,	Calculation of OLR, HRT	
Anaerobic system			
UASB	COD, T, pH, ORP, VFA, Alk,	Nutrients analysis; gas analysis	
AD	COD, T, pH, ORP, VFA, VFA/Alk,	Nutrients analysis; gas analysis	
Activated sludge	pH, DO, ORP, MLSS, MLVSS, SV ₃₀ , OUR	Nutrients analysis; calculation of sludge age, SVI, F/M ratio and SOUR	
MBR	pH, DO, ORP, MLSS, MLVSS, SVI, OUR, scouring air flowrate	Nutrients analysis, calculation of sludge age, age, F/M ratio and SOUR; membrane chemical cleaning	
Trickling filter	pH, DO, SS	Nutrients analysis, filter observations	
RBC	pH, DO, SS	Nutrients analysis, media observations	

Note: List not exhaustive; Graphs to be plotted depend on a case to case basis.

For activated sludge systems, you need to clearly identify the method of process control adopted at your plant (constant MLSS, constant F/M ratio, constant sludge age) and explain how the control is done on a daily basis.

It is recommended that you use several subparagraphs to present your discussion of the **PM procedure implemented** at your premise, **graphical plots** of PM data and **PM activities**. Examples of such subparagraphs may include the following:

EXAMPLES

3.1. PM procedure, sampling stations and frequency

You must explain the PM procedure implemented at your presmise and present a table of sampling stations, parameters/equipment readings and sampling frequency. (Example is shown below).

Table 3.....: Performance monitoring: sampling stations, parameters and frequency

Sampling station	Sampling parameters	Sampling frequency	Control range	Remarks
EQ outlet	Q, BOD, COD, pH, SS,	Daily (Q, pH,.....); Weekly (.....,.....)		
pH adjustment tank outlet	pH	Daily		
Activated sludge Aeration tank	pH, DO, MLSS, MLVSS, F/M, OUR, SOUR, SVI	Daily (pH, DO,...); Weekly (F/M,....)		
Others..				

3.1.1 Determination of control ranges

In this subchapter you are required to explain how the **control ranges** stated in Table 3... above are obtained. For example, pH in the metal hydroxide precipitation tank was obtained from the results of metal solubility test, or flowrate (Q), BOD, and COD used as the control were obtained from the maximum flowrate used by the consultant in the design, or F/M and sludge age ranges were obtained from the Guidance Document, etc.

EXAMPLES

(NOTE: At a minimum six months data are required for grpah plotting and reporting PM activities)




Fig 3.2: Metal hydroxide solubility test results

3.2 Discussion of PM data

Examples

3.2.1 Monitoring of EQ

In this subparagraph you must present and discuss graphical plots of the monitored parameters (e.g. pH, BOD, etc) versus time.




Fig 3.1: pH of EQ effluent versus day (Jan 1 to Jan 30, 2017)




Fig 3.2: COD concentration of EQ effluent versus day (Jan 1 to Jan 30 2017)

Fig 3.3: Others.....

3.2.2 Monitoring of pH adjustment in pH adjustment tank

In this subparagraph you must present and discuss graphical plots of pH versus time.



Fig 3.??.....: pH in pH adjustment tank versus day (Jan 1 to Jan 30 2017)

3.2.3 Monitoring of activated sludge system

3.2.3.1 Activated sludge system process control

In this subparagraph you must discuss the **method of process control** adopted for your AS system. The method may either be the constant sludge age method, the constant MLS method, or the constant F/M ratio method. Explain how the control is done on a daily basis.

3.2.3.2 Discussion of performance monitoring data

In this subparagraph you must present **graphical plots** of the monitored parameters (e.g. DO, MLSS, MLVSS, F/M ratio, OUR, SOUR, SVI, etc) versus time and discuss them by comparing the values obtained with the control/recommended ranges. Any data falling out of the recommended ranges needs to be explained.




Fig 3.5: DO versus day in aeration tank ((Jan 1 to Jan 30, 2017)




Fig 3.6: MLSS versus day ((Jan 1 to Jan 30, 2017)




Fig 3.7: F/M ratio versus day ((Jan 1 to Jan 30 2017)

Fig 3.8 and for other parameters

3.2.4. Monitoring of adsorption process in activated carbon column

In this subparagraph you must present and discuss **graphical plots** of the monitored parameters (e.g. COD, etc) versus time. You must also identify clearly the method used for monitoring the column breakthrough time.




Fig 3.9: COD concentration of effluent of activated carbon adsorption column versus day (Jan 1 to Jan 30 2017)

3.2.... Monitoring of.....etc

Note: Continue the discussion on all the monitored parameters using the graphical plots

3.3 Other PM activities

3.3.1 Jar testing

3.3.2 Instrument calibration

3.3.3 Equipment and instrument maintenance

Any of the above items when mentioned and discussed in the FTR must be provided with **evidence**, placed in the Appendices. For example jar test results can be presented in the form of graphical plots and coagulant dosage calculations. The evidence for instrument calibration and maintenance activities would be the photocopies of calibration records and maintenance schedules.

3.4 Compliance monitoring

In this subchapter you must present and discuss graphical plots of the significant parameters (plus the **discharge standards as the control limits**) monitored at the final discharge point or points. Make a **conclusion** on the status of compliance based on the graphs presented. It is recommended that you present your discussion in subparagraphs as follows (depending on the parameters):

EXAMPLES

3.4.1 pH at FDP



Fig 3... pH at the FDP versus day (January 1-30, 201..)

3.4.2 COD at FDP




Fig 3... COD at the FDP versus day (January 1-30, 201..)

3.4.3 SS at FDP




Fig 3... NH₃ at the FDP versus day (January 1-30, 201..)

3.4.4 etc...

CHAPTER 4: UPSET CONDITIONS AND CORRECTIVE ACTIONS

In this chapter you are required to describe the **details of upset conditions** encountered, if any, during the operation of LTS for the duration of the FTR preparation. You must provide information on the nature of upset conditions, when they happened, why they happened, who discovered them, what corrective actions were taken, and how long it took to fix the problems. The upset conditions may be “minor” which may last only for a short duration and simple corrective action may promptly fix the problem. The minor upset should not result in a discharge noncompliance. On the other hand, an upset condition may be classified as “major” which may last for several hours or longer and results in serious implications such as discharge noncompliance or landfill/transfer station shutdown. In such a situation substantial **corrective actions** may be necessary to restore conditions to normalcy. Both for the minor and major upsets, you must also discuss what **preventive measures** (hardware, procedure, etc.) have been put in place by you and the management of your landfill/transfer station to prevent the problems from recurring.

You may want to present your discussion in subparagraphs as follow:

4.1 Minor upsets

4.2 Major upsets

4.3 Preventive measures

Evidence in the form of photographs, internal memos, purchase requests, bills paid for corrective actions and preventive measures, etc. must be provided for the items mentioned or discussed in this chapter.

CHAPTER 5: FURTHER IMPROVEMENTS

In this chapter, you are required to describe what **future efforts**, beyond the FTR preparation period, if any, have been initiated by you to further improve environmental regulatory compliance and ensure smooth running of the LTS on a

sustained basis. The proposed initiatives/projects must have been discussed at the EPMC meetings and some form of endorsement or commitment has been obtained from the management. The **improvement initiatives** may be “hardware” in nature or “software or nonhardware” in character. Evidence in the form of EPMC meeting minutes, equipment purchase requisition, or implementation schedule must be provided in the Appendix. Potential areas for improvement may include IETS upgrading, environmental staffing and training, LTS data management, communication, reporting, etc. Present your discussion in subparagraphs wherever appropriate, such as:

5.1 Hardware improvements

5.2 “Nonhardware” improvements

CHAPTER 6: CONCLUSIONS

In this chapter, you are required to make some conclusions on the **overall performance** of your LTS and to discuss how performance monitoring and the CePLTPO certification program have **benefited** you and your landfill or transfer station organization/company. The aspects to discuss should cover such areas as knowledge and skill, image, PM data management, LTS maintenance, regulatory compliance, etc.

C APPENDICES

Appendices serve as evidence of the items or subjects or improvements mentioned in the main text.

Among others, the appendices may include the following:

Appendix I

List and photographs of performance monitoring equipment/instruments (Model number, Manufacturer) used for conducting performance monitoring activities

Appendix II

An example of Minutes of the EPMC meetings

Appendix III

An example of the LTS Performance Monitoring Report submitted to the EPMC or management at the headquarters

Appendix IV

Revised or new field log sheet for monitoring..... with two signatures

Appendix V

Example of jar test results and coagulant dose calculations

Appendix VI

PM instruments calibration records

Appendix VII

Proofs of corrective actions

Appendix VIII

PM instruments maintenance schedule

Appendix IX

Further improvements: Implementation schedule (if relevant)

Appendix X

Further improvements: Equipment purchase requisition (if relevant)

Etc....

(Note: Modify the list of Appendices to suit your needs. Ensure to provide evidence for whatever is discussed in the text of your FTR)

References

(NOTE: REFER TO YOUR COURSE NOTES FOR DETAILS ON PERFORMANCE MONITORING REQUIREMENTS FOR THE VARIOUS TREATMENT PROCESSES/COMPONENTS OF YOUR LTS)

APPENDIX A

EXAMPLE OF THE SEQUENCE OF THE “CONTENTS” OF THE FTR
(From cover to appendices)

CERTIFIED ENVIRONMENTAL PROFESSIONAL IN THE OPERATION OF
LEACHATE TREATMENT SYSTEMS
(CePLTPO)

FIELD TRAINING REPORT


Submitted to

The Director
Environment Institute of Malaysia (EiMAS)
Department of Environment
Universiti Kebangsaan Malaysia Campus
Locked Bag No 24
43600 BANGI, Selangor

By

Abdul Rahim bin Abdul Rahman
Identity Card number:
September 30, 201.....

In Partial Fulfilment of the Requirement for the Certificate of Certified Environmental Professional in the Operation of Leachate Treatment Systems (CePLTPO)



A. General information on the candidate

A1. Name of CePLTPO candidate:

.....

A2. Contact address:

.....

.....

A3. Designation:

.....

A4. Date of attending the CePLTPO course:

.....

A5. Name and address of the landfill or transfer station where you underwent the field training on LTS operation and maintenance or supervision:

i) Name:.....

ii) Address:.....

.....

.....

A6. Period of field training:

.....

A7. Contact officer in your landfill or transfer station organization/company (e.g. Human Resource Manager at the headquarters) who could verify your training experience:

Name:.....

Designation:.....

Phone number:.....

Fax number:.....

E-mail address:.....

b. Verification (to be filled out by the candidate's supervisor)

"I hereby declare that (Mr/Ms).....has completed the minimum six months field training as required and the information provided in the FTR is true to my best knowledge"

Name of official or supervisor at the Headquarters:
 NRIC number:
 Designation :.....
 Signature: Date:
 Landfill or transfer station organization's/company's official stamp:

c. Declaration (to be filled out by the CePLTPO candidate)

"I declare that the entire FTR is the product of my own work and all the facts stated in it and the accompanying information are true and correct and that I have not withheld or distorted any material facts or included any materials plagiarized from other FTRs"

Name of candidate:..... NRIC number:
 Designation :.....
 Signature: Date:
 Landfill or transfer station organization's/company's official stamp:

TABLE OF CONTENTS

General information on the candidate	i
Verification	iii
Declaration	iv
List of tables	v
List of figures	vi
List of abbreviations	vii

Chapter 1: Introduction

Chapter 2: Performance monitoring of leachate treatment system

Chapter 3: Discussion of performance monitoring activities and results

Chapter 4: Upset conditions and corrective actions

Chapter 5: Further improvements

Chapter 6: Conclusions

References

Appendices

The requirements stipulated in this Guidance Document come into force immediately

DIRECTOR GENERAL
DEPARTMENT OF ENVIRONMENT
MALAYSIA
Date: June 2019

EIMAS CERTIFICATION CENTER/2019

FTR READINESS SELF ASSESSMENT FORM (For own use by the FTR preparer)

DOCUMENTATION

Item	Complied? (YES/NO)	Remarks
FTR specifications (hard cover, font, spacing, contents arrangement, etc.)		
FTR copies:hardcopy and CD		
Minimum six months training period		
FTR submission within stipulated period		
Verification and declaration with company stamp on company's letterhead		

MAIN TEXT

CHAPTER 1: INTRODUCTION

Items	YES/NO?	Remarks
1.1 Background (sufficient details given?)		
1.2 Environmental commitment		
EP (stand alone and strongly worded?)		
EF (all facilities described?)		
EB (figures provided?)		
EC (organizational structure and training plan provided?)		
CePLTPO's job description provided?		
EPMC (organizational structure, TOR, meeting dates records provided)		
ERCMC (information on committee		

members and meeting date provided)		
ERC (information on internal reporting requirements provided?)		
ET (information on environmental report, or CSR activities, if any, provided?)		

CHAPTER 2: PERFORMANCE MONITORING OF LTS

Items	YES/NO?	Remarks
2.1 Activities and leachate generation (Activities described, raw leachate table provided?) (leachate type, biodegradability discussed?, nutrient deficiency discussed?) (significant leachate parameters identified?)		
2.2 Description of LTS (LTS flowchart and explanation, table of LTS design and operating details provided?)		
2.3 Conduct of LTS performance monitoring (situation before course attendance discussed?) (changes instituted discussed, evidence provided?)?		

CHAPTER 3: DISCUSSION OF PERFORMANCE MONITORING RESULTS

Items	YES/NO?	Remarks
3.1. PM procedure, sampling stations and frequency (PM procedure explained?) (table on Performance monitoring: sampling stations, etc.. provided?) (if activated sludge: process control used explained?)		
3.2 Discussion of PM data (graphs of all relevant data plotted with control ranges and satisfactorily discussed?)		
3.3 Other PM activities (discussed satisfactorily with evidence?)		
3.4 Compliance monitoring (graphs of all significant parameters plotted and discussed?)		

CHAPTER 4: : UPSET CONDITIONS AND CORRECTIVE ACTIONS

Items	YES/NO?	Remarks
4.1 Minor upsets (adequately discussed with evidence?)		
4.2 Major upsets (discussed with adequate details with evidence?)		
4.3 Preventive measures (adequately discussed with evidence?)		

CHAPTER 5: FURTHER IMPROVEMENTS

Items	YES/NO?	Remarks
5.1 Hardware improvements (adequately discussed with evidence?)		
5.2 Nonhardware improvements (adequately discussed with evidence?)		

CHAPTER 6: CONCLUSIONS

Items	YES/NO?	Remarks
Conclusions adequately discussed?		

APPENDICES

Items	YES/NO?	Remarks
1. Photographs of of analytical equipment (photos plus details on model number, manufacturer- All provided?)		
2. Minutes of the EPMC meetings (formally endorsed?)		
3. LTS Performance Monitoring Report (formally endorsed?)		
4. Revised or new PM field log sheets (Used with handwritten entries and two signatures provided?)		
5. Jar test results (graphs and coagulant dosing calculations provided?)		
6. Further improvements: Implementation schedule (if relevant) provided?		
7. Further improvements: EPMC meeting minutes discussing further improvement		

projects provided? Equipment purchase requisition (if relevant) provided?		
8. Proofs related to minor upset conditions provided?		
9. Proofs related to major upset conditions Provided		
10. Equipment and instrument maintenance records provided?		
11. PM instruments calibration records provided?		
12. Others....		

REMINDERS

Submit only the complete FTRs

If you have answered YES to all those items in the above table, then you are ready to submit your FTR to EiMAS. DO NOT submit INCOMPLETE FTR (i.e. any items answered NO). It will be REJECTED WITHOUT the FTR BEING REVIEWED.

Policy on plagiarism

EiMAS places great importance to technical integrity especially in written submissions for approval and certification purposes. Plagiarism will not be tolerated. Plagiarism is to use another person's work and pretend that it is one's own. A FTR containing any plagiarized material especially plagiarized from other FTRs will AUTOMATICALLY BE REJECTED AND BE GIVEN A "FAIL" GRADE. The FTR will be returned to the submitter and a letter of rejection sent to the manager of the company the submitter is attached to.

EiMAS Certification Center
June 2019